

ADVISORY NO. 8.2: LABORATORY AUDITS

PURPOSE AND PROCEDURE

The laboratory, with all of the hazardous substances and electrical equipment contained in it, can pose a potential safety hazard if not properly maintained and if safe laboratory procedures are not followed. The potential for injury not only exists for those working in the lab, but also to people working nearby as in the case of a release of a hazardous substance or a fire.

To minimize the University's efforts to minimize the potential hazards in laboratories, the Office of Environmental Health and Safety is required to audit all laboratories and provide feedback to stakeholders (e.g. principal investigator, lab manager, etc.) on potential hazards and to provide technical assistance in eliminating/minimizing risks. To get the most out of the audit program and reduce interruptions of research programs, EH&S developed three types of audits, i.e., Project Specific Audits, common or emerging laboratory issues and develop target priorities. Referral Audits are used to follow-up on regulatory compliance issues or unsafe or unhealthy conditions. Announced Audits focus on a particular issue such as use and functioning of laboratory fume hoods.

The audit results are sent via email to the Principal Investigator responsible for the laboratory, usually within a week of the laboratory audit. It is the responsibility of the Principal Investigator to correct the issues identified. Resolution of the audit issues is tracked and the Principal Investigator is contacted regarding resolution of outstanding issues and to provide technical assistance, if necessary. The department Business Administrator or other senior managers in the responsible department may be alerted, where appropriate, if audit issues require further resolution. For a general lab inspection checklist for the use of Principal Investigator or any other Laboratory member for internal audits or a general list of what EH&S evaluates during audits see Appendix A. Please note that the inspection checklist in Appendix A is only a generalization of the scope of the EH&S laboratory safety audit.

SCOPE

A standard form will be used for all laboratory audits. The items, which will be checked, will include the following:

Electrical

If there is a fume hood alarm or another type of environmental alarm, is it working properly and has it been tested? Is there clear access to the electrical panel in case of fire or other emergency?
Is all electrical equipment properly grounded? Do any electric cords have frayed or damaged insulation? Are there an excessive number of extension cords in use?

Fire

Is a fire extinguisher present in the lab or is there one nearby? Is the extinguisher being inspected on a monthly basis? Are all aisles clear?

Housekeeping

Are the bench top work areas, and the lab as a whole, kept clean? Is there evidence of eating or drinking in the lab?

Chemical Storage

Are all chemicals segregated and stored according to chemical class (e.g. acids and bases segregated, flammables separated from oxidizers, reactives isolated, etc.)? Are flammables stored in flammable storage cabinets? Are there more than 10 gallons of flammables stored in the room outside of flammable storage cabinets? If there are ethers or other peroxide-formers stored in the lab for more than 3 months, have they been tested for the formation of peroxides? Are all bottles clearly labeled with their contents? Are all gas cylinders secured?

Waste

Is there a glass disposal receptacle present and labeled as such? If needles, razor blades or other sharp objects are used, is there a sharps container present for their disposal? Is all chemical waste properly collected and labeled? Is all infectious waste autoclaved before disposal or otherwise treated appropriately?

Ventilation

Are there any room vents which are blocked or obstructed in any way? Are there excessive amounts of bottles or equipment stored in the fume hoods? Are fume hoods properly installed and ducted to prevent cross contamination and exposure? Are the fume hoods working properly? During lab audits, all fume hoods in the room will be checked to see if they have an adequate face velocity.

Emergency

Is there an eyewash and shower in the lab or nearby? Does the lab have a spill kit adequate for a spill of any of the chemicals used there? Are emergency procedures for fire, chemical spills and other types of emergencies clearly posted in the lab near the door?

Miscellaneous

Is there any exposed friable asbestos in the room? Is the entrance to the room clearly labeled with applicable hazard warning signs such as the radiation hazard sign or the biohazard sign? Is there a laboratory file (or a central department file) containing Material Safety Data Sheets (MSDS) for all chemicals used?

ADVISORY NO. 8.2:
Appendix A

LABORATORY AUDITS
CHECKLIST

GENERAL LAB INSPECTION CHECKLIST

Additional pages can be attached for site specific information. If you have questions or suggestions regarding the content of this survey, please contact Jan Utrecht, Environmental Health and Safety at 556-4968

Company/Principal Investigator: _____ Dept: _____

Building: _____ Room: _____

Lab Contact: _____

Work Phone: _____ Home Phone: _____

Completed by: _____

Date: _____

5) Control

- Chemicals are not stored on laboratory benches in excessive quantities.
- Expired or out of use chemicals are disposed of as hazardous waste.
- Area for carcinogen use should be labeled.
- Secondary containment provided for liquid chemicals.
- No hazardous materials are stored next to or above sinks.
- Incompatible chemicals (including solids) segregated by compatible storage groups.
- All chemical containers closed, except when actively adding or removing materials from them (i.e., no funnels left in containers).
- Containers of peroxide-forming chemicals are dated upon receipt and disposed of when six-month shelf life is exceeded.
- Material Safety Data Sheets (MSDSs) and laboratory chemical inventory list are readily available.

Y	N	N/A	COMMENTS/DATE CORRECTED

6) Flammable/Combustible Liquids

- What is the quantity of class 1A liquids?
- If there are more than 10 gallons of flammable liquids, does the lab. have the necessary fire permits?
- How many flammable liquid storage cabinets are in the room and what is the capacity of each?
- Storage cabinets do not exceed maximum capacity.
- Flammable liquids (including flammable liquid wastes) are not stored outside of a storage cabinet in excess of 10 gallons.
- No flammable liquid storage cabinets are in the hallways.
- Flammables are not dispensed from gravity-fed or bottom-dispensing containers—use lid-mounted pumps (including <5% Ethanol solutions).
- Flammables are not stored in combustible containers.
- Ether and other highly-flammable liquids are used away from sources of heat and ignition (including Bunsen burners in hoods and gas water heaters).

Y	N	N/A	COMMENTS/DATE CORRECTED

7) Particularly Hazardous Substances

- Have all particularly hazardous substances been identified?
- Are areas or hoods where these substances are in use posted with a designated area sign?
- Have special procedures for these substances been identified?
- Are special procedures in practice?
- Are the users adequately trained?

Y	N	N/A	COMMENTS/DATE CORRECTED

8) Radioactive Materials

- All uses of radioactive material are authorized through the RSO?
- Stock materials of radioactive materials are secured against unauthorized removal? Refrigerator locked? Etc.
- Do personnel wear lab coats and radiation dosimeters when handling material?

Y	N	N/A	COMMENTS/DATE CORRECTED

